

From

The Member-Secretary,
Chennai Metropolitan
Development Authority
8 Gandhi Irwin Road,
Chennai-600 008.

Letter No.B3/19550/95

To

The Commissioner,
Corporation of Chennai,
Ripon Building, Chennai-600 003.

Dated: 27.12.96.

Sir,

YATRAHOTI - CHENNAI 703

Sub: CMDA - Area Plans Unit - Planning Permission
- Proposed additional construction of GF Shopping
Complex for TUCS at S.No.382/1 of Peravallur village - T.S.No.1pt. Block No.32, Periyar Nagar - Approved - Reg.

Ref: 1. PPA recd. vide Ir.No.WDC No.D4/PPA No.2902/95 dtd. 30.8.95.
2. R.P. recd. on 15.4.96. & 16.10.96.
3. This office Ir.even No.dtd. 12.6.96.
4. Your lr. dtd. 27.6.96.
5. Lr.No. CMSSB/SE(PD)S/PP/1015/96, dt.2.12.96.

*** ADMO , CEST, MHD
(asif bevoque te ope nitiw)

The Planning Permission application and Revised plan received in the reference 2nd cited for the proposed additional construction of Ground Floor Shopping Complex for TUCS at S.No. 382/1 of T.S.No. 1Pt. Block No.32 of Peravallur village, Periyar Nagar has been approved subject to the conditions incorporated in the reference 3rd cited.

2. You have remitted the necessary charges in Challan No. 75280, dated 26.6.96 accepting the conditions stipulated by CMDA vide in the reference 4th cited.

3. As per the Chennai Metropolitan Water Supply and Sewerage Board letter cited in the reference 5th cited with reference to the sewerage system the promoter has to submit the necessary sanitary application directly to Metro water and only after due sanction he can commence the internal sewer works.

In respect of water supply, it may be possible for Metro water to extend water supply to a single sump for the above premises for the purpose of drinking and cooking only and confined to 5 persons per dwelling at the rate of 10 lpcd. In respect of requirements of water for other uses, the promoter has to ensure that he can make alternate arrangements. In this case also, the promoter should apply for the water connection, after approval of the sanitary proposal and internal works should be taken up only after the approval of the water application. It shall be ensured that all wells, overhead tanks and Septic tanks are hermetically sealed with properly protected vents to avoid mosquito menace.

4. One copy/set of approved plans numbered as Planning Permit No. B/24448/583/96, dated 27.12.96 are sent herewith. The Planning Permit is valid for the period from 27.12.96 to 26.12.99.

p.t.o.

